



**Summary of Substantive Changes  
between the 2009 and the 2013 editions of  
ASTM B306, “Copper Drainage Tube (DWV)”**

**Presented to the IAPMO Standards Review Committee on June 10, 2013**

**General:** The changes to this standard should not have an impact on currently listed products. The changes are:

- Clarified that tensile testing is an option in the contract or purchase order (see Sections 4.2.1 and 8.1.2)

Section 4. Ordering Information: clarified that tensile testing is an option in the contract or purchase order as follows:

*4.2 The following options are available and shall be specified in the contract or purchase order when required:*

*[4.2.1 Tensile Test \(Section 8.1\)](#)*

Section 8, Mechanical Property Requirements: Clarified that tensile testing is only required if specified by purchase order contract as follows:

*[Section 8.1.2, Tensile tests need not be performed except when specified in the contract or purchase order.](#)*