



**Summary of Substantive Changes  
between the 2009 and the 2011 editions of  
ASTM C700, "Vitrified Clay Pipe, Extra Strength,  
Standard Strength, and Perforated"**

**Presented to the IAPMO Standards Review Committee on March 12, 2012**

**General:** Changes to this standard are editorial and should not affect current listings.

Section 6, Allowable Limits for Dimensional Variation:

Section 6.2: This section was revised as follows:

*The inside diameter shall not vary from a true circle by more than 3% of its nominal diameter measured at any one location along the pipe barrel.*