



**Summary of Substantive Changes  
between the 2008 and the 2013 editions of  
ASTM F679 “Poly(Vinyl Chloride) (PVC) Large-Diameter Plastic Gravity  
Sewer Pipe and Fittings”**

**Presented to the IAPMO Standards Review Committee on November 4, 2013**

**General: General:** The changes to this standard should not have an impact on currently listed products. The major change is:

- Expanded the scope to include 54 in and 60 in pipe and fittings (see Section 1.1)

Section 1, Scope: Expanded the scope to include 54 in and 60 in pipe and fittings as follows;

*1.1 This specification covers requirements and test methods for materials, dimensions, workmanship, flattening resistance, impact resistance, pipe stiffness, extrusion quality, joining system, and a form of marking for large diameters, 18 to ~~48 in~~60 in. poly(vinyl chloride) (PVC) sewer pipe and fittings with integral bell elastomeric seal joints and smooth inner walls.*

Table 1, Pipe Dimensions and Minimum Pipe Stiffness: Added requirements for 54 in and 60 in pipe.